



**SOLICITATION ADDENDUM**

Solicitation Number: RFP 17-15      Addendum #1      Page 1 of 4

Solicitation Due Date: October 13, 2016, 2:00 p.m. (Local Time)

**CITY OF GLENDALE**  
Materials Management  
5850 W. Glendale Avenue  
Suite 317  
Glendale, AZ 85301  
Phone: (623) 930-2865

**RFP 17-15**

**LARGE WATER METERS AND PARTS**

As a result of the pre-offer conference held on Tuesday, October 4, 2016, the following revisions have been made to Request for Proposals No. 17-15:

**BID DUE DATE AND TIME:**

**Changed:**

**From: OCTOBER 11, 2016 BEFORE 2:00 P.M. LOCAL TIME**

**To: **OCTOBER 13, 2016** BEFORE 2:00 P.M. LOCAL TIME**

**1.2 GENERAL AND TECHNICAL SPECIFICATIONS**

**Change to Section 1.2.10.1:**

The main case shall be made from ductile iron with an approved NSF epoxy coating. The main case shall have a test port, **an integral strainer** and an easily removable independent measuring chamber/~~strainer~~ for maintenance; and

**Change to Section 1.2.10.2:**

Measuring chamber assembly shall include a floating ball impeller with a coated titanium shaft, hybrid axial bearings, integral flow straightener, and ~~an~~ **a single** all-electronic programmable register with protective bonnet.

**Change to Section 1.2.11:**

Omni meters shall have ~~an~~ **a single** electronic hermetically sealed register with an electronic pickup containing no mechanical gearing;

**1.3 COMMERCIAL/INDUSTRIAL/**RESIDENTIAL** WATER METERS:**

**Add to Section 1.3.1:**

**Series “Omni T2” Turbo**

<b><u>MODEL</u></b>	<b><u>SIZE</u></b>
Omni T2 with flange connections	1 ½”
Omni T2 with flange connections	2”
Omni T2	3”
Omni T2	4”
Omni T2	6”
<b>Omni T2 with flange connections,</b>	<b>10” (without strainer – 2”)</b>



**SOLICITATION ADDENDUM**

**CITY OF GLENDALE**  
Materials Management  
5850 W. Glendale Avenue  
Suite 317  
Glendale, AZ 85301  
Phone: (623) 930-2865

Solicitation Number: RFP 17-15      Addendum #1      Page 2 of 4  
Solicitation Due Date: October 13, 2016, 2:00 p.m. (Local Time)

**Change Section 1.3.2:**

**Fire Hydrant Meters**

<u>MODEL</u>	<u>SIZE</u>
<del>125 W fire hydrant meter equipped with fire hose</del>	<del>3" swivel couplings</del>
OMNI H2 Fire Hydrant Meter	3"
With national standard fire hose thread male adapter and female swivel coupling	

**Change Section 1.3.4:**

Portable Large Meter Tester: ~~MODEL: Detector W 1250~~

<u>MODEL</u>	<u>SIZE</u>
OMNI 3 V2 Tester	3"
SRII	5/8" x 3/4"
SRII	1"



**SOLICITATION ADDENDUM**

Solicitation Number: RFP 17-15      Addendum #1      Page 3 of 4  
 Solicitation Due Date: October 13, 2016, 2:00 p.m. (Local Time)

**CITY OF GLENDALE**  
 Materials Management  
 5850 W. Glendale Avenue  
 Suite 317  
 Glendale, AZ 85301  
 Phone: (623) 930-2865

**Replace Section 5 in its entirety with the “revised” Bidding Schedule**

**5.0 BIDDING SCHEDULE (Revised)**

Bidders shall thoroughly complete the Price Sheet as requested. The Unit Price shall include, but is not limited to, shipping, labor, equipment, tools, materials, supplies, licenses, fees, insurance, profit, and any other associated direct or indirect costs. **Sales tax shall not be included in the Unit Price.**

<b>5.1 METER PRICING</b>					
<b>Item No.</b>	<b>Estimated Quantities (A)</b>	<b>Description</b>	<b>Unit Price (B)</b>	<b>Extended Amount (A X B)</b>	<b>DISCOUNT % OFF MSRP FOR PARTS</b>
5.1.1	25	1 ½” OMNI T2 Turbo Meter	\$ _____	\$ _____	
5.1.2	40	2” OMNI T2 Turbo Meter	\$ _____	\$ _____	
5.1.3	3	3” OMNI T2 Turbo Meter	\$ _____	\$ _____	
5.1.4	3	4” OMNI T2 Turbo Meter	\$ _____	\$ _____	
5.1.5	3	6” OMNI T2 Turbo Meter	\$ _____	\$ _____	
5.1.6	1	3” OMNI C2 Compound Meter	\$ _____	\$ _____	
5.1.7	1	4” OMNI C2 Compound Meter	\$ _____	\$ _____	
5.1.8	1	6” OMNI C2 Compound Meter	\$ _____	\$ _____	
5.1.9	1	10” OMNI T2 with flange connections, without strainer – 2”	\$ _____	\$ _____	
5.1.10	25	3” OMNI H2 Fire Hydrant Meter with national standard fire hose thread male adapter and female swivel coupling	\$ _____	\$ _____	
5.1.11	1	5/8” x 3/4 SRII Positive Displacement Meter	\$ _____	\$ _____	
5.1.12	1	1” SRII Positive Displacement Meter	\$ _____	\$ _____	



**SOLICITATION ADDENDUM**

Solicitation Number: RFP 17-15      Addendum #1      Page 4 of 4

Solicitation Due Date: October 13, 2016, 2:00 p.m. (Local Time)

**CITY OF GLENDALE**  
Materials Management  
5850 W. Glendale Avenue  
Suite 317  
Glendale, AZ 85301  
Phone: (623) 930-2865

5.1.13	1	OMNI 3 V2 Tester	\$ _____	\$ _____	
--------	---	------------------	----------	----------	--

<b>GRAND TOTAL (Item Nos. 5.1.1 through 5.1.12 Extended Amounts)</b>	\$ _____
--	----------

**5.2 TAX AMOUNT** Bidders should not include transaction use tax or federal tax in their unit price. The City is exempt from the payment of federal excise tax and will add use tax as applicable. For the purpose of determining the lowest cost, the City will not take tax into consideration.

Tax: \_\_\_\_\_%

**5.3 DELIVERY** Bidder states that all orders shall be delivered within **45** calendar days after receipt of purchase order, contract release document or written notice to proceed from the City of Glendale.

**5.4 PROCUREMENT CARD ORDERING CAPABILITY** Please check appropriate box.

\_\_\_\_ YES, I will accept payment under this contract with the Procurement Card.

\_\_\_\_ NO, I will not accept payment under this contract with the Procurement Card.

**5.5 DISCOUNT/PAYMENT TERMS:** The City standard is 2% 20 days.

Comply: YES \_\_\_\_\_ NO \_\_\_\_\_

If your answer is NO, please state terms offered:

Name of Company: \_\_\_\_\_

Address: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

Print Name and Title: \_\_\_\_\_