



## SOLICITATION ADDENDUM

Solicitation Number: RFP 19-20      Addendum #1      Page 1 of 8

Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

**CITY OF GLENDALE**  
Procurement Division  
5850 W. Glendale Avenue  
Suite 317  
Glendale, AZ 85301  
Phone: (623) 930-2864

### **RFP 19-20**

#### Generator Maintenance

As a result of the pre-offer conference conducted on January 24, 2019, the following revisions and clarifications have been made to Request for Proposals No. 19-20:

#### **Proposal Due Date Changed to February 14, 2019 at 2:00 P.M. Local Time.**

##### **CLARIFICATION:**

1. Section 1, Item 1.2.9

Service or replace air filter if needed: Change to inspect air filter. Air filter replacement will be charged as an additional service.

Power Washing – change to Visual inspection only and that Power Washing and/or Steam Cleaning will be charged as an additional service.

2 Hour Load Banking Test at 100%: Change to 2 Hour Load Banking Test at 80% per NFPA 110 guidelines.

2. Section 1, Item 1.2.12 Specifications

Add that Fuel quality test will be performed semi-annually per ASTM 975 Standards. Test to include Varnish, Bio Diesel and Petroxy test as needed.

3. Section 3.1.2 Pricing for Annual Maintenance Including Parts and Labor:

Change June Annual Maintenance Cost Per Unit to **September** Annual Maintenance Cost Per Unit.

##### **ADDITION:**

1. Add Section 1, Item 1.2.13

- The contractor shall be responsible for providing all maintenance related run-time information as a result of preventive maintenance, testing, and repair service
  - o Provide and maintain a written log book on site documenting the following:
    - Date and time of the service
    - Description of the service
    - Beginning hour meter reading
    - Ending hour meter reading
  - o Provide the above information on each field report submitted for any service, and make the information available on line through the customer portal



**SOLICITATION ADDENDUM**

**CITY OF GLENDALE**  
**Procurement Division**  
**5850 W. Glendale Avenue**  
**Suite 317**  
**Glendale, AZ 85301**  
**Phone: (623) 930-2864**

Solicitation Number: RFP 19-20      Addendum #1      Page 2 of 8

Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

**ADD:**

**1.5 Generator Information**

<b>Generator</b>	<b>Address</b>	<b>Manufacturer</b>	<b>Model No.</b>	<b>Tank Capacity</b>	<b>Voltage</b>	<b>Serial No.</b>
1500 KW Caterpillar (Two Units)	5901 North Glen Harbor Boulevard	CAT			12,470	6WN00351
1500 KW Caterpillar (Two Units)	5901 North Glen Harbor Boulevard	CAT			12,478	6WN00353
1000 KW Caterpillar	9802 West Camelback Road	Cummins/ONAN	DFHD- 5635416		480	K030567449
500 KW Caterpillar	6893 North Glen Harbor Boulevard	CAT	3492		480	TM4372
125 KW Onan	111719 West Glendale Avenue	Onan	DGEA- 4477361		480	C000075351
225 KW Cummins	14904 North 67 <sup>th</sup> Avenue	Cummins	B4-3533		480	465-139
40 KW Kohler	12995 North 55 <sup>th</sup> Avenue	Kohler	40ROZ201		480	1888859
100 KW Onan	5175 West Arrowhead Lakes Drive	Onan	GGHD- 3382578		480	L990029512
350KW Onan	6790 West Deer Valley Road	Onan	350DFCC		480	H910414694
1100 KW Caterpillar	7970 West Bethany Home Road	CAT	3512DITA		480	24207636



**SOLICITATION ADDENDUM**

**CITY OF GLENDALE**  
**Procurement Division**  
**5850 W. Glendale Avenue**  
**Suite 317**  
**Glendale, AZ 85301**  
**Phone: (623) 930-2864**

Solicitation Number: RFP 19-20      Addendum #1      Page 3 of 8

Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

750 KW Onan	4805 West Cholla Street	Onan	750DFHA		480	B980695115
300 KW Onan	4805 West Cholla	Onan	300DFCB		480	B000065349
75 KW Onan	4805 West Cholla	Onan	50DGCA		480	G000132099
1250 KW Detroit Diesel (Two Units)	8180 West Union Hills	Spectrum	1250DS		480	606822
1250 KW Detroit Diesel (Two Units)	8180 West Union Hills	Spectrum	1250DS		480	606821
300 KW Cummins	17500 North 83 <sup>rd</sup> Avenue	Cummins	300DFCB		480	B050750996
350 KW Generac	19600 North 79 <sup>th</sup> Avenue	Generac	1490020200		480	2062208
600 KW Detroit Diesel	28101 North 63 <sup>rd</sup> Avenue	Detroit	1646806741		480	818677305
1750 KW Cummins (Two Units)	7070 West Northern Avenue	Cummins	1750DQKB		480	I060976129
1750 KW Cummins (Two Units)	7070 West Northern Avenue	Cummins	1750DQKB		480	H060960117
<b>Generator</b>	<b>Address</b>	<b>Manufacturer</b>	<b>Model Year</b>	<b>Tank Capacity</b>	<b>Voltage</b>	<b>Serial No.</b>
275 KW Onan	5850 West Glendale Avenue	Onan	1982	250	275	E820621105
150 KW Generac	6210 W Myrtle	Generac	1998	100	150	2041295



**SOLICITATION ADDENDUM**

**CITY OF GLENDALE**  
**Procurement Division**  
**5850 W. Glendale Avenue**  
**Suite 317**  
**Glendale, AZ 85301**  
**Phone: (623) 930-2864**

Solicitation Number: RFP 19-20      Addendum #1      Page 4 of 8

Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

125 KW Cummins	5959 W Brown Street	Cummins	1987	250	125	J860850572
250 KW Kohler	6835 N 57th Drive	Kohler	1992	250	250	278865
1000 KW Cummins Diesel (Two Units)	11550 W Glendale Avenue	Cummins	2006	1700	1000	I060967892
1000 KW Cummins Diesel (Two Units)	11550 W Glendale Avenue	Cummins	2006	145	80	J060982093
50 KW Kohler (Two Units)	6801 N Glen Harbor – Tower	Kohler	1998	100	50	392690
50 KW Kohler (Two Units)	6801 N Glen Harbor	Generac	1987	100	50	0812338
15 KW Generac	4439 W Peoria	Generac	1983	100	15	0720042
50 KW Katolight	14061 N 59th Avenue	Katolight	1998	100	50	642937 60275
80 KW Cummins	17159 N 63rd Avenue	Cummins	2005	145	80	C050764494
100 KW Generac	6255 W Union Hills Drive	Generac	1985	250	100	860889
40 KW Katolight	6801 W Deer Valley Rd	Katolight	1999	100	40	LM642746 60276
80 KW Generac	9658 N 59th Avenue	Generac	1997	100	80	2034170
250 KW Generac	6851 North 52nd Avenue	Generac		100	250	2100792



**SOLICITATION ADDENDUM**

**CITY OF GLENDALE**  
**Procurement Division**  
**5850 W. Glendale Avenue**  
**Suite 317**  
**Glendale, AZ 85301**  
**Phone: (623) 930-2864**

Solicitation Number: RFP 19-20      Addendum #1      Page 5 of 8

Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

230 KW Cummins	6261 N 83rd Avenue	Cummins	2003	420	230	B030464839
50 KW Katolight	6850 W Bethany Home Road	Katolight	2000	100	50	642939 60279
30 KW Katolight	7505 N 55th Ave	Katolight			30	LM643599 60269
80 KW Multiquip (Two Units)	7505 N 55th Ave – Mobile 1	Multiquip			80	PE4045T685550
80 KW Multiquip (Two Units)	7505 N 55th Ave – Mobile 2	Multiquip			80	PE4045T66369
43 KW Hipower	7505 N 55th Ave	Hipower	2012		43	X1CH43543
60 KW Generac	11480 W Glendale Ave	Generac	2016	100	60	9713694



**SOLICITATION ADDENDUM**

Solicitation Number: RFP 19-20      Addendum #1      Page 6 of 8  
 Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

**CITY OF GLENDALE**  
 Procurement Division  
 5850 W. Glendale Avenue  
 Suite 317  
 Glendale, AZ 85301  
 Phone: (623) 930-2864

**ADD to Pricing Workbook:**

<b>Generator</b>	<b>Address</b>	<b>Facility Name</b>	<b>Battery Change Cost Per Unit (Two Years)</b>
1500 KW Caterpillar (Two Units)	5901 North Glen Harbor Boulevard	West Area Water Reclamation Facility	\$
1000 KW Caterpillar	9802 West Camelback Road	Raw Sewage Pump Station	\$
500 KW Caterpillar	6893 North Glen Harbor Boulevard	Airport Lift Station	\$
125 KW Onan	111719 West Glendale Avenue	Aquifer Recharge Facility	\$
225 KW Cummins	14904 North 67 <sup>th</sup> Avenue	67 <sup>th</sup> and AC/DC Lift Station	\$
40 KW Kohler	12995 North 55 <sup>th</sup> Avenue	55 <sup>th</sup> and Dahlia Lift Station	\$
100 KW Onan	5175 West Arrowhead Lakes Drive	Arrowhead Manor Booster Station	\$
350KW Onan	6790 West Deer Valley Road	Hillcrest Ranch Booster Station	\$
1100 KW Caterpillar	7970 West Bethany Home Road	Zone Four Reservoir	\$
750 KW Onan	4805 West Cholla Street	Zone One Booster Station	\$
300 KW Onan	4805 West Cholla	Cholla Admin	\$
75 KW Onan	4805 West Cholla	Cholla Chlorine Scrubber	\$
1250 KW Detroit Diesel (Two Units)	8180 West Union Hills	Arrowhead Ranch Water Reclamation Facility	\$
300 KW Cummins	17500 North 83 <sup>rd</sup> Avenue	83 <sup>rd</sup> Avenue Lift Station	\$
350 KW Generac	19600 North 79 <sup>th</sup> Avenue	Oasis Recharge Site	\$
600 KW Detroit Diesel	28101 North 63 <sup>rd</sup> Avenue	Pyramid Peak	\$
1750 KW Cummins (Two Units)	7070 West Northern Avenue	Oasis Water Treatment Plant	\$
275 KW Onan	5850 West Glendale Avenue	Glendale City Hall	\$
150 KW Generac	6210 W Myrtle	OPS Complex	\$
125 KW Cummins	5959 W Brown Street	Glendale Main City Library	\$



**SOLICITATION ADDENDUM**

**CITY OF GLENDALE**  
**Procurement Division**  
**5850 W. Glendale Avenue**  
**Suite 317**  
**Glendale, AZ 85301**  
**Phone: (623) 930-2864**

Solicitation Number: RFP 19-20      Addendum #1      Page 7 of 8

Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

250 KW Kohler	6835 N 57th Drive	Main Police Station	\$
1000 KW Cummins Diesel (Two Units)	11550 W Glendale Avenue	Glendale Regional Training Center	\$
50 KW Kohler (Two Units)	6801 N Glen Harbor	Glendale Airport	\$
15 KW Generac	4439 W Peoria	Fire Station 154	\$
50 KW Katolight	14061 N 59th Avenue	Fire Station 153	\$
80 KW Cummins	17159 N 63rd Avenue	Fire Station 159	\$
100 KW Generac	6255 W Union Hills Drive	Fire Station 155	\$
40 KW Katolight	6801 W Deer Valley Rd	Fire Station 156	\$
80 KW Generac	9658 N 59th Avenue	Fire Station 157	\$
250 KW Generac	6851 North 52nd Avenue	Fire Station 151	\$
230 KW Cummins	6261 N 83rd Avenue	Fire Station 158	\$
50 KW Katolight	6850 W Bethany Home Road	Fire Station 152	\$
30 KW Katolight	7505 N 55th Ave	Fire Support	\$
80 KW Multiquip (Two Units)	7505 N 55th Ave	Fire Support	\$
43 KW Hipower	7505 N 55th Ave	Fire Support	\$
60 KW Generac	11480 W Glendale Ave	Landfill	\$
<b>Total (3.1.5)</b>			<b>\$</b>



**SOLICITATION ADDENDUM**

Solicitation Number: RFP 19-20      Addendum #1      Page 8 of 8  
Solicitation Due Date: February 14, 2019, 2:00 p.m. (Local Time)

**CITY OF GLENDALE**  
Procurement Division  
5850 W. Glendale Avenue  
Suite 317  
Glendale, AZ 85301  
Phone: (623) 930-2864

**ADD to Pricing Workbook:**

**3.1.5 Pricing for Semi-Annual Fuel testing**

Fuel Testing per ASTM 975 Standards Varnish			\$	\$
Fuel Testing per ASTM 975 Standards Bio Diesel			\$	\$
Fuel Testing per ASTM 975 Standards Petroxy			\$	\$
<b>Total (3.1.6)</b>			<b>\$</b>	<b>\$</b>

Name of Company: \_\_\_\_\_

Address: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

Print Name and Title: \_\_\_\_\_